MUNICIPAL CORPORATION OF DELHI
OFFICE OF THE DY. HEALTH OFFICER
SHAHDARA NORTH ZONE

No.DHO/Shah (N)/2025/ 525 **Dated:** 10/11/25

SCHOOL INSPECTION REPORT

In reference to your application duly submitted in the office of undersigned vide diary No. 278 dated 03.11.2025, the inspection of **"BHAGWATI MEMORIAL PUBLIC SCHOOL ".** Situated at Main 33 Ft. Road, Shiv Vihar, Karawal Nagar, Delhi-110094 was carried out on dated 04.11.2025. During the inspection, it was found that the school is running under satisfactory sanitary & hygienic conditions, provision of latrines & urinals is sufficient according to the number of students and has safe drinking water facilities for the students and members of staff of the institution.

In view of the above findings, undersigned is hereby pleased to grant **'PROVISIONAL NO OBJECTION CERTIFICATE FROM HEALTH POINT OF VIEW'** to the above said school. This certificate is valid for a period of one year from the date of issue.

Dy. Health Officer
Shahdara North Zone
उप-स्वास्थ्य अधिकारी
शाहदरा उत्तरी क्षेत्र
दिल्ली नगर निगम

H.M.
BHAGWATI MEMORIAL PUBLIC SCHOOL
Main 33 Ft. Road, Shiv Vihar,
Karawal Nagar, Delhi-110094

ACWA-TYR
Diary No. 414 dt. 11.07.2025

Delhi Jal Board

No.DJB/QCLTYR/PD/250701

DELHI JAL BOARD
(GOVT. OF N.C.T. DELHI)
QUALITY CONTROL LABORATORY,
TRANS YAMUNA REGION TAHIRPUR DELHI-110093

BUREAU OF INDIAN STANDARDS IS / ISO 9001 QMS

Licence No- CRO/QM/L-8004274-1 as per IS/ISO 9001:2015

स्वच्छ भारत
एक कदम स्वच्छता की ओर

NO: DJB/ACWA(TYR)/2025/..... **DATE:- 10-07-2025**

Analysis report of DJB water supply samples collected from (1) Inlet(Before R.O.), (2) Outlet(After R.O.) of M/S BHAGWATI MEMORIAL PUBLIC SCHOOL, MAIN 33 FT. ROAD, SHIV VIHAR, KARAWAL NAGAR, DELHI-110094, for drinking purpose.

Ref. No. NIL
Challan No: - 107, dated: - 07.07.2025

Date of collection : 08-07-2025

S. No.	PARTICULARS	BIS:10500-2012 LIMITS		UNITS	RESULT	
		Desirable	Permissible		(1)	(2)
A.	Physical Examination					
1.	Colour	...	...	-	CLEAR	CLEAR
2.	Odour	...	...	-	UNOBJ.	UNOBJ.
3.	Turbidity	1.0	5.0	NTU	0.82	1.10
4.	pH Value	6.5-8.5	--	-	7.5	7.4
5.	Electrical Conductivity	--	--	µs/cm	2688	580
6.	Total Dissolved Solids	500	2000	mg/l	1747	377
B.	Chemical Examination					
7.	P^{th} Alkalinity	...	...	mg/l	NIL	NIL
8.	Total Alkalinity	200	600	mg/l	366	72
9.	Total Hardness	200	600	mg/l	338	54
10.	Calcium as (Ca)	75	200	mg/l	67.2	8.8
11.	Magnesium as (Mg)	30	100	mg/l	40.8	7.68
12.	Ammonical Nitrogen	0.5	NR	mg/l	N.D	N.D
13.	Nitrite	....	....	mg/l	N.D	N.D
14.	Nitrate	45	NR	mg/l	37.50	10.99
15.	Sulphate	200	400	mg/l	266.04	41.75
16.	Chloride	250	1000	mg/l	400	106
17.	Fluoride	1.0	1.5	mg/l	1.40	0.45
18.	Dissolved Iron	1.0	NR	mg/l	0.23	0.07
19.	Cyanide	0.05	NR	mg/l	N.D	N.D
20.	Residual Chlorine	0.2	1.0	mg/l	NIL	NIL
C.	Bacteriological Examination					
21.	Coliform count	Absent	NR	MPN/100ml	150	0

This Report Pertains To The Particular Sample Only

REMARKS:-(1) On the basis of above tested parameters, water sample (1) does not conform BIS: 10500-2012 and cannot be considered fit for drinking purpose.
(2) On the basis of above tested parameters, water sample (2) conforms BIS: 10500-2012 and can be considered fit for drinking purpose.

11/7/25
(Purushottam Singh)
ACWA(TYR)
Asstt. Chief Water Analyst
D.J.B. Govt. of N.C.T. of Delhi
Quality Control Zonal Laboratory (Tyr)
Tahir Pur Dilshad Garden, Delhi-93

A.G Susmitha 10.7.25
(A.G Susmitha)
BACTERIOLOGIST

10/7/25
(Gulesh Jainar)
CHEMIST

10.07.2025
(Mayank Yadav)
A/CHEMIST